

**Jacksonville University
Main Entrance / Welcome Center
Addendum #3**

Stellar RFI

JU ENTRY GATE RFI'S

No	RFI	Date Submitted	Date Answered
1	There is very minimal information on the girder pump station. Please provide more information for accurately pricing this item. Plumber to calculate size of pump based on one restroom and distance of sanitary pipe.	28-Jan	
2	At what elevation will the proposed force main pipe enter the existing sewer manhole? TBD	28-Jan	
3	Sheet C-3 shows a new grinder pump station. Is power for the new pump station to be supplied from the new electrical service? Circuit in the new electrical panel? Yes	28-Jan	
4	Sheet C-3 calls for "new electric service, see elec. site plan." We did not receive an electric site plan drawing. Please advise. DWG C-3 shows the service coming from an existing JU service cabinet to the west. Electrical subcontractor to determine size of feeders and new panel as written in Addendum #1.	28-Jan	
5	Sheet A101 – please provide location of where the phone & data from the owner will enter the building. Please advise. Provide two 2" PVC underground electrical conduits to Room 102 NE wall and 5' out of the building to the north.	28-Jan	
6	Please confirm a bid bond is not required. Not required.	28-Jan	
7	The given schedule shows a Certificate of Occupancy date of 3/30/10. Document A105-2007 pg. 4 lists the Substantial Completion date of 4/10/10. Please advise as to which date is correct? 4/10 Schedule will be adjusted.	28-Jan	
8	What is the finish of the storefront metal? Kynar metallic finish	28-Jan	
9	Is the insulated glass clear or does it have a tint? 1" VE6-85 insulated blue – Green-HS by Viracon or equivalent	28-Jan	
10	Is a Low-E coating required on the glass? Not required	28-Jan	
11	Is the storefront door a Narrow, Medium or Wide stile? Medium	28-Jan	
12	Please provide specified finish on fencing and gates (i.e., powder coat, Kynar, etc.) Black power coat finish, lifetime warranty.		
13	Has a color been selected for the brick pavers? Will there be multiple colors? Addendum #2, Page 1 – Tremron Heritage		