

**Jacksonville University
Main Entrance / Welcome Center
Addendum #4**

- * What is the type of brick on the knee walls at the very north and south of the entry area. Page A101 south end note says Type 2 and is shaded. North end - no note and is not shaded.

This brick will be Type 01

- * Will this area change to cast stone if alternate is accepted?
No

- * Style/shape of the concrete paver roadway. We know the manufacturer and color.

Per Addendum #2, they are 4x6

- * Re: security/data/phone - how are these being fed to the Guard House?

See Addendum #3, item #5

We had a call from Carson w/ PM with the following question.

Section 1/A103 calls for a traffic coating to be installed on top of the roof slab. The details call for a roof membrane. It was our intention to call the roof membrane the roof "system". The traffic coating will be installed where the "roof membrane" is called out as well.