

PROJECT: THE HAGEDORN AVIATION COMPLEX

OWNER: EMBRY RIDDLE AERONAUTICAL UNIVERSITY
600 S. Clyde Morris Blvd.
Daytona Beach, Florida 32114

ARCHITECT: HAWKINS, HALL, & OGLE ARCHITECTS, INC.
208 Magnolia Avenue
Daytona Beach, Florida 32114
386-255-6163 Fax: 386-257-5650

ADDENDUM NUMBER 5 DATED 19 January 2010

This addendum is part of the Contract Documents and modifies the Project Plans and Specifications as follows:

A5.1 ELECTRICAL CLARIFICATIONS:

1. Item 1 under the electrical clarifications in Addendum #2 stated that either EMT raceway or MC cable may be used for this project, except where specifically stated otherwise. As a clarification to this item, all EXPOSED power and lighting circuits shall be EMT, with flexible wiring to fixtures or final equipment connections. In addition, all fire alarm wiring shall be in EMT raceways.
2. In addendum #4, item number 3, strike the reference to 120V power supplies, these are provided by the hardware supplier, the electrical contractor only provides the power connections as indicated on the plans.

A5.2 SPECIFICATIONS: SECTION 08211 – FLUSH WOOD DOORS:

Clarification: Doors shall be Grade A Plain Sliced White Birch in lieu of the Quarter sliced Natural Birch previously specified.

END OF ADDENDUM NO. 5